



April 4, 2008 RE-ISSUED 06/26/09

AL'S CONCRETE PRODUCTS, INC.  
CHARLES MACH  
800 TOWNHALL ROAD  
LA CRESCENT MN 55947

Re: Description: **SEWAGE TREATMENT APPARATUS, FILTER CONTAINER/VAULT\***  
Manufacturer: AL'S CONCRETE PRODUCTS, INC.  
Product Name: SEDIMENTATION TANK  
Model Number(s): INLINE ZABEL FILTER CANISTER  
[for approved effluent filter installation]  
Product File No: 20080200

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The capacity of the sedimentation tank is exempt from the minimum capacity requirements of s. Comm 83.15 (3) of the Wis. Admin. Code. This tank capacity must not be included in the septic tank capacity required by s. Comm 83.15 (3) of the Wis. Admin. Code.
- The sedimentation tank must be installed downstream of septic tanks required by s. Comm 83.15 (3) of the Wis. Admin. Code.
- When Zabel filter model A100, A300 or A1800 is installed in this tank, installation must be in accordance with the filter manufacturer's printed instructions and the filter's product approval stipulations. If there is a conflict between the filter manufacturer's printed instructions and the filter's product approval stipulations, the product approval stipulations will take precedence.

This approval supersedes the approval issued on 3/26/2003/04/04/2008 under product file number 20030093/20080200. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030093/20080200.

**\* This product type category has been changed to better reflect it's use; it was previously approved as STA-sewage treatment apparatus; it is now listed as STAF CV- sewage treatment apparatus, container/vault.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov